

Government of Bihar
Public Health Engineering Department
District Level Water Testing Laboratory:- Siwan

Sample Collected by- Delhi Public School Basantpur, Siwan

Sample Receiving date:-05.02.2026

Sl No.	Date Of Testing	Block	Panchyat	Ward	Name of Scheme	Parameters															
						pH	Turb.	EC	TDS	TH	Ca	Mg	Cl	Alka.	Fe	NO ₃	SO ₄	F	As	Total Coll	
1	07.02.2026	Basantpur	Basantpur	-	Delhi Public School Basantpur, Siwan	7.01	0.5	-	192	68.40	16.35	6.10	32.4	65.30	0.16	BDL	BDL	0.18	0.00	<1.1	
IS: 10500:2012 (2nd Revision)						Acceptable Limit		Permissible Limits													
						6.5-8.5	1.0	-	200	200	75	30	250	200	0.3	45	200	1.0	0.01		
						8.5	5.0	-	500	600	200	100	1000	600	1.0	NR	400	1.5	NR		

Ajay Kumar
 Assistant Chemist D.L.W.T.L.
 P.H. Division, Siwan

07/02/26
 Chemist D.L.W.T.L.
 P.H. Division, Siwan

Annexure C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No.

Dated: 07-02-2026

It is certified that an inspection team headed by ... J.E. Basantir

(Name of Officers with designation) from ... Junior Engineer PHED

inspected the ... Delhi Public School, Basantir, Siwan

(Name & Address of the school) on 05-02-2026 ... (date of inspection) and on the basis of

Water Test Report (Attached) bearing no. ... D: 1200) dated 07-02-2026


of District Water Testing Lab, Siwan (PHED Lab) certified that

the ... Delhi Public School, Basantir (Name of school) has safe drinking water

facilities for the students and members of staff of the institution. School is also maintains the hygienic sanitation condition in the school building & the campus as per norms prescribed by the

Central/ State/ U.T. Govt.

This certificate is valid till ... One year

Signature with Seal:  07/02/2026

Name: Faizan Alam

Designation: Assistant Engineer

Name & Address of the Office / Department :

To

.....

.....

(Name & Address of the Institution)

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies